

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 10-10-2025

It is certified that an inspection team headed by Er. Ashish Chaudhary

(Name of Officers with designation) from JSV Sub-Division Haroli PHED

inspected the G.S.S. Badhera

(Name & Address of the school) on 10-10-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. WTL/25-327 dated 24-09-2025

of Jal Shakti Vibhag, Una No.1 (PHED Lab) certified that the

G.S.S. Badhera (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One Year

Self attested
AG

Signature with Seal:

Name: Er. Ashish Chaudhary

Designation: Asst. JSV Haroli

Name & Address of the Officer, Department: Assistant Engineer,

Jal Shakti Division

Haroli, Dist. Una (H.P.)

To

Principal

G.S.S. Badhera

Dist. Una (H.P.)

The Principal

G.S.S. Badhera, Dist. Una (H.P.)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

HIMACHAL PRADESH
WATER TESTING LABORATORY
JAL SHAKTI VIBHAG, UNA No.1

TEST REPORT

Test Report No: WTL/25- 327

Issue Date:- 24/01/2018

Sr. No.	Test	Result	Requirements As per IS 10500:2012	
			Acceptable Limit	Permissible limit in the absence of Alternate Source
Physical Parameters				
1.	Temperature (°C)	25.9°C	-----	-----
Chemical Parameters				
2.	Nitrate (as NO ₃), mg/l, Max	---	45 mg/l Max	No relaxation
3.	Fluoride (as F), mg/l, Max	---	1.0 mg/l Max	1.5 mg/l Max
4.	Sulphate (as SO ₄), mg/l, Max	---	200 mg/l Max	400 mg/l Max
5.	Ammonia (as total ammonia -N), mg/l, Max	---	0.5 mg/l Max	No relaxation
6.	Iron (as Fe), mg/l, Max	---	1.0 mg/l Max	No relaxation
7.	Manganese (as Mn), mg/l, Max	---	0.1 mg/l Max	0.3 mg/l Max
8.	Total Arsenic (as As), mg/l, Max	---	0.01 mg/l Max	No relaxation
9.	Free Residual Chlorine, mg/l, Min	0.09 mg/l	0.2 mg/l Min	1.0 mg/l Min

Remarks (if any) BDL= Below Detection Limit; DL= Detection Limit

Self attested

Principal
G.S.S.S. Balthera
Distt. Una 77209



Authorized Signatory
Mrs. Shikha Thakur
Water Testing Laboratory, Una No.1